

Fuel Storage And Handling | SAFE WORK METHOD STATEMENT (SWMS)

TASK OR ACTIVITY: Fuel Storage And Handling

Business Name: [Company Name]	ABN: [ABN]	SWMS#
Business Address: [Company Address]		
Contact Person:	Phone: [Phone]	Email:

THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PCBU OF THE PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: _____ Title: _____ Date: _____

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: _____ Title: _____ Phone: _____

ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED | **NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS**

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, to conduct and communicate those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary support to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

RISK MATRIX

LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard.
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	Administrative Change the work. PPE

Notes on Hierarchy of Controls: Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

PERSONAL PROTECTIVE EQUIPMENT (PPE)

FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE/FACE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>


Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

Note: A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

1. persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
2. persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
3. workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Unsecured equipment, Inadequate work area	2M	<ul style="list-style-type: none"> - Secure all equipment by following manufacturer guidelines and using appropriate securing methods, such as straps, chains, or locks, to prevent movement or displacement during operation or storage. - Regularly assess the work area for any obstructions, potential hazards, and its overall suitability for fuel storage and handling tasks to maintain an efficient and safe workspace. - Establish a designated storage area for fuel containers that is well-ventilated, free from ignition sources, and complies with relevant safety regulations and industry standards. - Implement clear and visible signage in the work area to alert workers and visitors about potential hazards and necessary precautions related to fuel storage and handling. - Develop and enforce strict protocols for handling, transporting, and disposing of fuel and related materials to minimise risks associated with spills, leaks, and environmental contamination. - Ensure all staff members are adequately trained in proper fuel storage and handling procedures, as well as the use and maintenance of necessary equipment to avoid workplace accidents. - Plan work sequences in advance to minimise clutter within the work area and ensure adequate space for both the operations and safe movement of personnel. - Keep an up-to-date inventory of fuel storage on site to manage the amount and type of fuel stored and to maintain compliance with local regulations and industry best practices. - Regularly inspect and maintain all tools, equipment, and personal protective equipment (PPE) used in fuel-related operations to mitigate risks related to unsecured or malfunctioning gear. - Prioritise communication and teamwork between staff members when performing fuel storage and handling tasks, ensuring that everyone is aware of their assigned tasks and potential hazards. - Establish emergency response procedures, including evacuation routes and assembly points, to prepare all personnel for swift action in case of accidents or emergencies dealing with fuel and hazardous materials. - Encourage a culture of reporting any incidents or near misses related to fuel storage and handling procedures so that lessons can be learned from past experiences, and necessary improvements can be implemented to promote overall workplace health and safety. 	1L	
2. Storage Site Selection	Unstable ground, Flammable materials nearby	3H	<ul style="list-style-type: none"> - Conduct a thorough site inspection to assess the ground stability before setting up fuel storage, ensuring the location has adequate support to handle the weight and volume of stored fuels. 	2M	



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Design, install and maintain a well-ventilated storage area to minimise the buildup of flammable vapors near sources of ignition. - Establish a minimum safe distance for any flammable materials, equipment, and structures surrounding the fuel storage site to prevent their contact or exposure. - Install appropriate fire-resistant barriers or partitions between flammable materials and the designated fuel storage area as a precautionary measure against possible fires. - Maintain a clean and organized storage area by routinely removing waste materials and debris that may increase the risk of fire or create unsafe conditions around the fuel storage site. - Ensure the effective drainage of water within the storage site to reduce the risk of fuel spills contaminating the environment and causing additional hazards. - Train workers on proper handling and storage techniques, including the use of personal protective equipment (PPE), to minimise risks related to fuel storage. - Regularly inspect and monitor the fuel storage area for potential leaks or other signs of contamination, implementing emergency spill containment measures as necessary to safeguard against environmental damage. - Develop and enforce standard operating procedures (SOPs) for fuel storage, addressing safe fuel handling, transfer, and disposal in accordance with applicable regulations and guidelines. - Prepare an emergency response plan outlining appropriate actions in case of a fuel leak, spill, or explosion, and regularly conduct drills to familiarise team members with these protocols. - Display clear and visible signage within the fuel storage site, notifying workers of hazards and cautioning them to adhere to proper safety protocols while handling and storing fuel. 		
3. Container Inspection	Corrosion, Damaged seals	3H	<ul style="list-style-type: none"> - Regular visual inspection: Conduct routine visual inspections of fuel containers at specific intervals to identify signs of corrosion or damage to seals, with increased frequency during periods of harsh weather conditions. - Proper container selection: Select appropriate and approved fuel storage containers to avoid any possible chemical reactions that could lead to corrosion or seal damage over time. - Adequate cleaning and maintenance: Schedule regular cleaning and maintenance activities to ensure the integrity and cleanliness of the fuel containers and to identify potential issues early on before they exacerbate. - Protective coatings: Apply protective coatings on the exterior of fuel containers to protect against potential corrosion or damage from outside factors. - Inspection records: Keep thorough records of inspection findings to monitor any trends in container deterioration and help inform future preventive actions. 	1L	

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Employee training: Train employees in proper fuel storage and handling practices, emphasising the importance of container inspections and hazard reporting. - Chemical compatibility checks: Ensure fuel being stored is compatible with the container material to minimise the risk of chemical corrosion. - Seal replacement: Replace damaged seals and gaskets immediately upon discovery to prevent fuel leakage. - Isolation of damaged containers: Immediately isolate any containers with corrosion or damaged seals from the rest of the fuel storage area to prevent contamination. - Proper disposal: Dispose of corroded or damaged containers following regulatory requirements and industry best practices, ensuring they do not cause further environmental or safety hazards. - Hazardous chemicals signage: Post warning signage near fuel storage areas identifying risks of corrosion and other hazards associated with fuel storage to raise employee awareness and encourage proper handling procedures. - Emergency response plan: Develop and communicate a clear emergency response plan for employees in the case of fuel leakage or container failure that outlines proper steps to control and contain the situation. 		
4. Correct Signage	Missing placards, Incorrect signs	2M	<p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p> <p>[REDACTED]</p>	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
5. Stability Assessment	Uneven terrain, Ground movement	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
6. Spill Containment	Inadequate spill protection, Unusable absorbent materials	3H	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
7. Fire Prevention	Ignition sources, Inadequate fire suppression	4A	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
8. Ventilation Assessment	Poor airflow, Presence of fumes	3H	[Redacted]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
9. Personal Protective Equipment	Incorrect size, Insufficient quantity	2M		1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
10. Safe Handling Procedures	Inappropriate tools, Inappropriate handling method		[REDACTED]	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
11. Emergency Response Plan	No plan in place, trained staff	4A	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
12. Cleanup and Disposal	Incorrect disposal methods, Unsafe handling of hazardous waste	3H	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

<p>Queensland & Australian Capital Territory Work Health and Safety Act 2011 Work Health and Safety Regulations 2011 Legislation QLD: https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws Codes of Practice QLD: https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice Legislation ACT: https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations Codes of Practice ACT: https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice</p>	<p>Victoria Occupational Health and Safety Act 2004 Occupational Health and Safety Regulations 2017 Legislation VIC: https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations Codes of Practice VIC: https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice</p>
<p>New South Wales Work Health and Safety Act 2011 Work Health and Safety Regulations 2017 Legislation NSW: https://www.safework.nsw.gov.au/legal-obligations/legislation Codes of Practice NSW: https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice</p>	<p>Western Australia Work Health and Safety Act 2020 Work Health and Safety Regulations 2022 Legislation Western Australia: https://www.commerce.wa.gov.au/worksafe/legislation Codes of Practice WA: https://www.commerce.wa.gov.au/worksafe/codes-practice</p>
<p>Northern Territory Work Health and Safety (National Uniform Legislation) Act 2011 Work Health and Safety (National Uniform Legislation) Regulations 2011 Legislation NT: https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws Codes of Practice NT: https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice</p>	<p>Safe Work Australia Links Law and Regulation (All States): https://www.safeworkaustralia.gov.au/law-and-regulation Model Codes of Practice: https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice</p>
<p>South Australia Work Health and Safety Act 2012 (SA) Work Health and Safety Regulations 2012 (SA) Legislation for SA: https://www.safework.sa.gov.au/resources/legislation Codes of Practice for SA: https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs</p>	<p>Model Codes of Practice</p> <ul style="list-style-type: none"> - Managing noise and preventing hearing loss at work - Confined spaces - Labelling of workplace hazardous chemicals - Managing risks of hazardous chemicals in the workplace - Welding processes - First aid in the workplace - Managing the risk of falls at workplaces - Hazardous manual tasks - Managing the risk of falls in housing construction - Managing electrical risks in the workplace - Demolition work - Excavation work - Work health and safety consultation, cooperation and coordination - Managing the work environment and facilities - How to manage work health and safety risks - Managing risks of plant in the workplace - Construction work
<p>Tasmania Work Health and Safety Act 2012 Work Health and Safety (Transitional and Consequential Provisions) Act 2012 Work Health and Safety Regulations 2012 Work Health and Safety (Transitional) Regulations 2012 Legislation for TAS: https://worksafe.tas.gov.au/topics/laws-and-compliance/acts-and-regulations Codes of Practice for TAS: https://worksafe.tas.gov.au/topics/laws-and-compliance/codes-of-practice</p> <p>Details of permits, licenses or access required by regulatory bodies (add or delete as required):</p> <ul style="list-style-type: none"> - Permits from local council - Authorisation to commence work - Any required documents. 	

SIGNATORIES OF THE SAFE WORK METHOD STATEMENT

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

SAFE WORK METHOD STATEMENT MONITORING AND REVIEW

The SWMS must be reviewed regularly to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

The SWMS must be monitored regularly for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST

This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.

ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
REVIEWED BY		DATE REVIEWED	
SIGNATURE		DATE COMPLETED	