

Genie Lift | SAFE WORK METHOD STATEMENT (SWMS)

TASK OR ACTIVITY: Genie Lift

Business Name: [Company Name]	ABN: [ABN]	SWMS#
Business Address: [Company Address]		
Contact Person:	Phone: [Phone]	Email:

THIS SAFE WORK METHOD STATEMENT IS APPROVED BY THE PROJECT MANAGER OF THE PROJECT

Under the Work Health and Safety Regulation (WHS Regulation), a person conducting a business or undertaking (PCBU) is required to ensure that a safe work method statement (SWMS) is prepared before the proposed work starts.

Full Name:

Signature: _____ Title: _____ Date: _____

Details of the person(s) responsible for ensuring implementation, monitoring and compliance of the SWMS, as well as reviews and modifications of the SWMS.

Full Name: _____ Title: _____ Phone: _____

ALL PERSONNEL PARTICIPATING IN ANY ACTIVITY ON THIS SWMS MUST HAVE THE FOLLOWING COMMUNICATED

NAME AND DATED SIGNATURE OF ALL RELEVANT PERSONNEL WHO HAVE BEEN CONSULTED AND COMMUNICATED TO IN THE DEVELOPMENT AND APPROVAL OF THIS SWMS

	NAME	SIGNATURE	DATE
Safety meetings or toolbox talks will be scheduled in accordance with legislative requirements to first identify any site hazards, to conduct a risk assessment of those hazards and then to further take steps to either eliminate or control each hazard.			
If an incident or a near miss occurs, all work must stop immediately. Depending on the severity of the incident, a meeting will be called with all workers to amend the SWMS if required. The meeting may also be an educational opportunity.			
Any changes made to the SWMS after an incident or a near miss must be approved by the Person Conducting Business or Undertaking and communicated to all relevant personnel.			
The SWMS must be kept and be available for inspection at least until the work is completed. Where a SWMS is revised, all versions should be kept. If a notifiable incident occurs in relation to which the SWMS relates, then the SWMS must be kept for at least two years from the occurrence of the notifiable incident.			

CLIENT OR PRINCIPAL CONTRACTOR DETAILS

Client:	SCOPE OF WORKS Provide a detailed description of the specific work being carried out (otherwise known as scope of works).
Project Name:	
Project Address:	
Project Manager:	
Contact Phone:	
Project Manager Signature:	
Date SWMS supplied to Project Manager:	

ANY HIGH-RISK CONSTRUCTION WORK BEING CARRIED OUT

<input type="checkbox"/> involves a risk of a person falling more than 2 meters.	<input type="checkbox"/> is carried out on or near pressurised gas mains or piping.
<input type="checkbox"/> is carried out on a telecommunication tower.	<input type="checkbox"/> is carried out on or near chemical, fuel or refrigerant lines.
<input type="checkbox"/> involves demolition of an element of a structure that is load-bearing.	<input type="checkbox"/> is carried out on or near energised electrical installations or services.
<input type="checkbox"/> involves demolition of an element related to the physical integrity of a structure.	<input type="checkbox"/> is carried out in an area that may have a contaminated or flammable atmosphere.
<input type="checkbox"/> involves, or is likely to involve, disturbing asbestos.	<input type="checkbox"/> involves tilt-up or precast concrete.
<input type="checkbox"/> involves structural alteration or repair that requires temporary support to prevent collapse.	<input type="checkbox"/> is carried out on, in or adjacent to a road, railway, shipping lane or other traffic corridor.
<input type="checkbox"/> is carried out in or near a confined space.	<input type="checkbox"/> is carried out in an area of a workplace where there is any movement of powered mobile plant.
<input type="checkbox"/> is carried out in/near a shaft or trench deeper than 1.5m or tunnel involving use of explosives.	<input type="checkbox"/> is carried out in areas with artificial extremes of temperature.
<input type="checkbox"/> is carried out in or near water or other liquid that involves a risk of drowning.	<input type="checkbox"/> involves diving work.

ANY HIGH-RISK MACHINERY OR EQUIPMENT NEARBY

<input type="checkbox"/> Forklift	<input type="checkbox"/> Crane/s	<input type="checkbox"/> Hoist/s	<input type="checkbox"/> Excavator	<input type="checkbox"/> Backhoe/Loader	<input type="checkbox"/> Boom Lift	<input type="checkbox"/> EWP	<input type="checkbox"/> Genie Lift
<input type="checkbox"/> Trencher	<input type="checkbox"/> Drilling Rig	<input type="checkbox"/> Trucks	<input type="checkbox"/> Formwork	<input type="checkbox"/> Bobcat	<input type="checkbox"/> Flammable Gas	<input type="checkbox"/> Fuel	<input type="checkbox"/> Dozer
<input type="checkbox"/> High Voltage	<input type="checkbox"/> Mulcher	<input type="checkbox"/> Tilt-up Panels	<input type="checkbox"/> Roller	<input type="checkbox"/> Scissor Lift	<input type="checkbox"/> Tractor	<input type="checkbox"/> Other -	

RISK MATRIX

LIKELIHOOD	INSIGNIFICANT	MINOR	MODERATE	MAJOR	CATASTROPHIC	SCORE	ACTION	HEIRARCHY OF CONTROLS
ALMOST CERTAIN	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4 ACUTE			Elimination Remove the hazard.
LIKELY	2 MODERATE	3 HIGH	3 HIGH	4 ACUTE	4 ACUTE	4A ACUTE	DO NOT PROCEED	Substitution Replace the hazard.
POSSIBLE	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	4 ACUTE	3H HIGH	Review before work starts.	Isolation Isolate People from the hazard
UNLIKELY	1 LOW	1 LOW	2 MODERATE	3 HIGH	4 ACUTE	2M MODERATE	Ensure control measures in place.	Engineering Isolate the hazard.
RARE	1 LOW	1 LOW	2 MODERATE	3 HIGH	3 HIGH	1L LOW	Monitor and keep records	Administrative Change the work. PPE

Notes on Hierarchy of Controls: Elimination methods are the most effective and preferred when controlling a hazard. Substitution is the second most effective method of controlling a hazard. Engineering by isolation is the third most effective, while Administrative Controls by changing the work is the fourth most effective method. PPE (Personal Protective Equipment) is the least effective method.

PERSONAL PROTECTIVE EQUIPMENT (PPE)

FOOT PROTECTION	HAND PROTECTION	HEAD PROTECTION	HEARING PROTECTION	EYE/FACE PROTECTION	RESPIRATORY PROTECTION	FACE PROTECTION	HIGH-VIS CLOTHING	PROTECTIVE CLOTHING	FALL PROTECTION	SUN PROTECTION	HAIR/JEWELLERY SECURED
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>


Select the appropriate PPE above suitable for the equipment used or the job task being performed (if applicable).

Note: A SWMS must be reviewed regularly to make sure it remains effective. A SWMS must be reviewed (and revised if necessary) if relevant control measures are revised. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.


When a SWMS has been revised, the person conducting a business or undertaking must ensure all:

1. persons involved in the work are advised that a revision has been made and how they can access the revised SWMS;
2. persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS; and,
3. workers that will be involved in the work are provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
1. Preparation	Unsafe ground conditions, Environmental hazards (e.g., wind, rain)	3H	<ul style="list-style-type: none"> - Ensure the ground conditions are assessed and inspected for stability and suitability before the Genie Lift is set up, including checking for any underground utilities. - Identify and discuss any specific environmental hazards and their potential impact on the operation during regular safety meetings and toolbox talks. - Consult weather forecasts and monitor real-time weather updates throughout the day to make informed decisions about wind, rain, and other potential environmental hazards. - Establish exclusion zones around the area where the Genie Lift will be operating and restrict unauthorised access to prevent potential accidents. - Utilise appropriate anchoring systems, such as outriggers or stabilizers, to support the Genie Lift and maintain stability during operation. - Implement an effective communication system between ground personnel, machine operators, and site supervisors to coordinate and monitor the safe progress of work activities. - Create an emergency response plan that includes procedure in case of sudden adverse weather conditions, equipment malfunction, or other unforeseen hazards. - Ensure that all workers have received suitable training, instruction and supervision in operating the Genie Lift safely and in managing relevant risks associated with the task. - Perform routine maintenance and inspections of the Genie Lift, according to manufacturer recommendations, to ensure it remains in good working condition, reducing the likelihood of component failure during operation. - Provide workers with personal protective equipment (PPE) necessary to protect against hazards, such as hard hats, safety glasses, high visibility vests and steel-toed boots. - Employ a designated spotter who will monitor the surroundings, communicate with the Genie Lift operator, and guide them as needed to avoid obstacles or unstable surfaces. - Use portable barriers, signage or cones to mark out the work area and highlight potential hazards, such as uneven terrain, trenches, and drop-offs. - Address any reported or identified hazards immediately, by taking corrective actions or utilising appropriate personal protective equipment and safe work methods. 	2M	
2. Pre-operational Inspection	Damaged equipment, Unauthorised use	3H	<ul style="list-style-type: none"> - Conduct thorough pre-operational inspections of the Genie Lift before each use to identify any signs of damage or wear that may compromise its safety and performance. 	1L	



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Develop and implement a robust maintenance programme for the Genie Lift, including regular servicing and repairs as needed to ensure all equipment remains in optimal working condition at all times. - Clearly label the Genie Lift's operating instructions on the equipment itself, and provide comprehensive training to all employees who are authorised to operate it, ensuring they understand their responsibilities and the necessary safety measures. - Establish designated areas for storing the Genie Lift when not in use, and ensure all employees are aware of its proper storage procedure in order to minimise the risk of unauthorised usage. - Only allow properly trained and certified employees to operate the Genie Lift, helping to minimise the risk associated with improper handling or operation. - Install safety features such as alarm, motion sensors, or lockout devices on the Genie Lift to deter unauthorised use and increase overall safety. - Create a logbook system that requires operators to sign off on inspections and maintenance performed on the Genie Lift, ensuring accountability and consistency in meeting safety standards and requirements. - Regularly review and update your company's health and safety policies regarding the operation, maintenance, and storage of the Genie Lift, ensuring staff members remain well-informed and up-to-date on best practices. - Encourage open communication among employees, allowing them to voice concerns about the Genie Lift's safety or potential hazards that they have encountered during its operation. - Provide ongoing safety training and refreshers for employees who are authorised to use the Genie Lift, reiterating key safety precautions and addressing any newly identified risks as they arise. 		
3. Setting up the Genie Lift	Wrong site placement, Obstructions/Barricades	3H	<ul style="list-style-type: none"> - Site assessment: Prior to setting up the Genie Lift, conduct a thorough site assessment to ensure appropriate placement and identify any potential hazards or obstructions, such as uneven ground or overhead cables. - Establish clear boundaries: Set up barricades and safety signage around the Genie Lift area, ensuring that unauthorised personnel and heavy machinery are kept at a safe distance during lift operation. - Verify ground conditions: Check the stability of the ground where the Genie Lift will be set up, making sure it's level, firm, and free from loose materials that could compromise its stability. - Consult manufacturer guidelines: Always follow the manufacturer's recommendations for safe use, setup, and weight capacity limits to reduce the risk of accidents related to incorrect operation. - Regular inspections: Inspect the Genie Lift before each use, conducting checks on base support, tires, emergency brakes, and other safety features to ensure proper functionality and safety compliance. 	2M	



JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			<ul style="list-style-type: none"> - Equipment maintenance: Conduct regular maintenance on the Genie Lift according to the manufacturer's specifications, addressing any mechanical or safety issues promptly. - Trained operators: Ensure that only trained and certified operators are allowed to operate the Genie Lift, preventing mishandling and associated risks. - Emergency response plan: Develop an emergency response plan specific to the Genie Lift operations, detailing appropriate communication channels and evacuation procedures in case of an incident. - Worksite communication: Implement clear communication protocols between the lift operator and other members of the team, ensuring everyone is aware of the lift's location and movements at all times. - Proper lifting techniques: Train operators in proper lifting techniques, avoiding sudden movements or jolting loads that may cause the lift to become unstable. - Load distribution: Pay attention to the load distribution of materials on the Genie Lift platform, ensuring it stays within specified weight limits and balancing loads evenly to prevent the risk of tipping over. 		
4. Accessing the Work Area	Falls from height, Struck by falling objects	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
5. Lifting Materials/Moving Loads	Overloading the lift, Crushing accidents	3H	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
6. Operating Controls	Lift failure, Upsetting/overturning of the lift	4A	[REDACTED]	2M	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
7. Communication	Miscommunication, Noise interference	2M	[REDACTED]	1L	
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
8. Emergency Procedures	Fire, Electrical incidents	4A		2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
9. Working in Restricted Areas	Underground services, Overhead services	3H	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
10. Dismantling Activities	Dropping heavy parts, Mishandling equipment	3H	[REDACTED]	2M	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		
			[Redacted]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
11. Housekeeping during work	Poor housekeeping, Slip/Trip/Falls		[REDACTED]	1L	
12. Posting Completion	Inadequate final inspection, Poor documentation	2M	[REDACTED]	1L	

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

JOB STEP	POTENTIAL HAZARDS	IR	CONTROL MEASURES	RR	RESPONSIBLE PERSON
SPECIFIC WORK STEPS	HAZARDS THAT MAY ARISE	INITIAL RISK	SPECIFIC MEASURES TO BE PUT IN PLACE TO ELIMINATE OR CONTROL THE RISKS	RESIDUAL RISK	NAME OF PERSON
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		
			[REDACTED]		

SAMPLE

EMERGENCY RESPONSE – CALL 000 FOR EMERGENCIES

Ensure to have an Emergency Management Plan in place as well as adequate numbers of trained first aid staff with easy access to fully stocked first aid kits, rescue equipment, material safety data sheets, adequate access to emergency communication equipment and fire-fighting equipment suitable for all classes of fire and ignition sources.

LEGISLATIVE REFERENCES

RELEVANT LEGISLATION AND CODES OF PRACTICE. DELETE THE LEGISLATIVE REFERENCES FOR ANY STATE THAT ARE NOT APPLICABLE

<p>Queensland & Australian Capital Territory Work Health and Safety Act 2011 Work Health and Safety Regulations 2011 Legislation QLD: https://www.worksafe.qld.gov.au/laws-and-compliance/work-health-and-safety-laws Codes of Practice QLD: https://www.worksafe.qld.gov.au/laws-and-compliance/codes-of-practice Legislation ACT: https://www.worksafe.act.gov.au/laws-and-compliance/acts-and-regulations Codes of Practice ACT: https://www.worksafe.act.gov.au/laws-and-compliance/codes-of-practice</p>	<p>Victoria Occupational Health and Safety Act 2004 Occupational Health and Safety Regulations 2017 Legislation VIC: https://www.worksafe.vic.gov.au/occupational-health-and-safety-act-and-regulations Codes of Practice VIC: https://www.worksafe.vic.gov.au/compliance-codes-and-codes-practice</p>
<p>New South Wales Work Health and Safety Act 2011 Work Health and Safety Regulations 2017 Legislation NSW: https://www.safework.nsw.gov.au/legal-obligations/legislation Codes of Practice NSW: https://www.safework.nsw.gov.au/resource-library/list-of-codes-of-practice</p>	<p>Western Australia Work Health and Safety Act 2020 Work Health and Safety Regulations 2022 Legislation Western Australia: https://www.commerce.wa.gov.au/worksafe/legislation Codes of Practice WA: https://www.commerce.wa.gov.au/worksafe/codes-practice</p>
<p>Northern Territory Work Health and Safety (National Uniform Legislation) Act 2011 Work Health and Safety (National Uniform Legislation) Regulations 2011 Legislation NT: https://worksafe.nt.gov.au/laws-and-compliance/workplaces-and-laws Codes of Practice NT: https://worksafe.nt.gov.au/laws-and-compliance/codes-of-practice</p>	<p>Safe Work Australia Links Law and Regulation (All States): https://www.safeworkaustralia.gov.au/law-and-regulation Model Codes of Practice: https://www.safeworkaustralia.gov.au/resources-publications/model-codes-of-practice</p>
<p>South Australia Work Health and Safety Act 2012 (SA) Work Health and Safety Regulations 2012 (SA) Legislation for SA: https://www.safework.sa.gov.au/resources/legislation Codes of Practice for SA: https://www.safework.sa.gov.au/workplaces/codes-of-practice#COPs</p>	<p>Model Codes of Practice</p> <ul style="list-style-type: none"> - Managing noise and preventing hearing loss at work - Confined spaces - Labelling of workplace hazardous chemicals - Managing risks of hazardous chemicals in the workplace - Welding processes - First aid in the workplace - Managing the risk of falls at workplaces - Hazardous manual tasks - Managing the risk of falls in housing construction - Managing electrical risks in the workplace - Demolition work - Excavation work - Work health and safety consultation, cooperation and coordination - Managing the work environment and facilities - How to manage work health and safety risks - Managing risks of plant in the workplace - Construction work
<p>Details of permits, licenses or access required by regulatory bodies (add or delete as required):</p> <ul style="list-style-type: none"> - Permits from local council - Authorisation to commence work - Any required documents. 	

SIGNATORIES OF THE SAFE WORK METHOD STATEMENT

The signed and dated personnel listed below have cooperated in the consultation and development of this Safe Work Method Statement which has been approved by the Person/s Conducting a Business or Undertaking (PCBU). In signing this Safe Work Method Statement each individual acknowledges and confirms that they have read this SWMS in full, having raised any questions for items on this Safe Work Method Statement that require clarification, and confirms that they are competent, skilled and knowledgeable for the task assigned to them. Every person acknowledges that they have received the relevant training and qualifications where required, before carrying out any work contained in this Safe Work Method Statement. By signing this Safe Work Method Statement each individual agrees to work safely, to follow any safe work instructions which are provided, and agrees to use all Personal Protective Equipment where appropriate.

Worker Name	Position	Signature	Date	Time	Supervisor
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		
			Date:		

SAFE WORK METHOD STATEMENT MONITORING AND REVIEW

The SWMS must be reviewed regularly to make sure it remains effective and must be reviewed (and revised if necessary) if relevant control measures are needed. The review process should be carried out in consultation with workers (including contractors and subcontractors) who may be affected by the operation of the SWMS and their health and safety representatives who represented that work group at the workplace.

When the SWMS has been revised the PCBU must ensure that all persons involved with the work are advised that a revision has been made and how they can access the revised SWMS, including all persons who will need to change a work procedure or system as a result of the review are advised of the changes in a way that will enable them to implement their duties consistently with the revised SWMS. All workers that will be involved in the work must be provided with the relevant information and instruction that will assist them to understand and implement the revised SWMS.

The SWMS must be monitored regularly for the effectiveness of ensuring hazard controls are effective in reducing the risk of incidents, keeping the workplace safe for all personnel. The person responsible for monitoring the effectiveness of the Safe Work Method Statement should employ a multi-faceted approach which includes but is not limited to:

1. Spot Checks.
2. Consultation with workers, contractors and sub-contractors.
3. Internal audits on a continual basis.

An approach of continuous improvement, promptly recording inconsistencies or deficiencies, followed up by immediate corrective action and consultation with all relevant personnel ensures that the PCBU is consistently developing ever-improving systems of safe work principles.

REVIEW NUMBER	<input type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7
NAME							
INITIALS							
DATE							

SAFE WORK METHOD STATEMENT REVIEW CHECKLIST

This Safe Work Method Statement Review Checklist is to be followed and used upon initial development of the SWMS to help ensure that all steps have been adequately taken before work commences. Think of this document as an internal audit review checklist before commencing work, and may form part of a Toolbox Talk (safety meeting) and may be used as an opportunity for education and training.

ITEMS WHICH MUST BE INCLUDED IN THE SWMS	COMPLETED	TO BE DONE	COMMENTS
The company details have been entered, including the project name and address.	<input type="checkbox"/>	<input type="checkbox"/>	
Names and signatures of all relevant personnel consulted during the development of the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Name, signature, position and date signed of the person approving the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Specific personnel and qualifications, experience is noted in the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Provides a step-by-step process of tasks required to carry out the activity or task.	<input type="checkbox"/>	<input type="checkbox"/>	
Adequate risk assessment of any identified hazards has been completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Foreseeable hazards are identified and documented for each step.	<input type="checkbox"/>	<input type="checkbox"/>	
Any hazards listed in any site risk assessments have been added to the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS initial risk (IR) column as well as residual risk (RR) columns completed.	<input type="checkbox"/>	<input type="checkbox"/>	
Check control measures added to the SWMS are the most effective solutions.	<input type="checkbox"/>	<input type="checkbox"/>	
Responsible person is assigned and listed on the SWMS for the implementation of control measures.	<input type="checkbox"/>	<input type="checkbox"/>	
Permit requirements specified, such as Hot Work, Electrical Work, Work at Heights etc.	<input type="checkbox"/>	<input type="checkbox"/>	
SWMS identifies plant and equipment to be used.	<input type="checkbox"/>	<input type="checkbox"/>	
Details of inspection checks required for any equipment listed are noted on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Describes any mandatory qualifications, experience, training, skills required to perform the work.	<input type="checkbox"/>	<input type="checkbox"/>	
Applicable personal protective equipment is selected on the SWMS.	<input type="checkbox"/>	<input type="checkbox"/>	
Lists any required permits or licenses.	<input type="checkbox"/>	<input type="checkbox"/>	
Reflects and documents any legislative references and/or Australian Standards.	<input type="checkbox"/>	<input type="checkbox"/>	
Identifies any hazardous substances used with specific control measures in line with any SDS.	<input type="checkbox"/>	<input type="checkbox"/>	
REVIEWED BY		DATE REVIEWED	
SIGNATURE		DATE COMPLETED	